

ITEM	QTY	DESCRIPTION		MATERIAL
01	1	BODY	КОРПУС	ASTM A182 F91 / SA182 F91
02	1	SEAT	СЕДЛО	STELLITE
04	1	LOOSE BACKSEAT	РАЗЪЕМНАЯ ПРОБКА	AISI 304
05	1	STEM PACKING	НАБИВКА ШТОКА	GRAPHITE
07	1	GLAND / FLANGE	САПЬНИК / ФЛАНЕЦ	AISI 304 / CARBON STEEL
09	2	GLAND BOLT / NUT	ГАЙКА/БОЛТ САПЬНИКА	ASTM A193 B7 / A194 2H
11	1	STEM / DISC	ШТОК / ДИСК	17Cr / STELLITED
12	1	YOKE	ХОМУТ	CARBON STEEL
13	1	YOKE SLEEVE	ВТУЛКА ХОМУТА	AL-BRONZE
14	1	HANDWHEEL	МАХОВИК	CARBON STEEL
15	1	POSITION INDICATOR	ИНДИКАТОР ПОЛОЖЕНИЯ	17Cr
23	1	PARALLEL KEY	ПРИЗМ. ШПОНКА	STAINLESS STEEL
25	1	SET SCREW	РЕГУЛИРОВОЧНЫЙ ВИНТ	STEEL ZINC PLATED
27	2	SPRINGWASHER	ПРУЖИННАЯ ШАЙБА	STEEL ZINC PLATED
32	1	THIN NUT	НИЗКАЯ ГАЙКА	STEEL ZINC PLATED
44	1	NAMEPLATE	ШИЛЬДИК	ALUMINIUM

MAIN DIMENSIONS IN MM.									
ITEM NR.	NOM. SIZE	A	B	C	D	E	F	WEIGHT	CV-VALUE
143	20MM	18	16	230	263	38	200	7.7 KG.	6.1

MAIN DIMENSIONS IN INCHES									
NOM. SIZE	A	B	C	D	E	F	WEIGHT		
3/4"	0.71	0.63	9.06	10.35	1.50	7.87	17 LBS		


HP VALVES REF. : 20100006

APPROVAL : *Yrk*

PROJECT REFERENCE: YAJVINSKAYA CCPP

CLIENT P/O NO : 203/2010/900588

CLIENT : CMI

HP VALVES


P.O. Box 151
7570 AD Oldenzaal
The Netherlands
Tel +31 (0)541 519555
www.hpvalves.com
info@hpvalves.com

REQ. NUMBER: 239143

TAG NR.		DESIGN PRESS.	DESIGN TEMP.
15HAH10AA107		BAR (G)	°C
15HAH10AA108		142	557
15HAH10AA119		142	557
15HAH10AA120		142	545
15LBA10AA101		142	575
15LBA10AA102		142	575
Spare Valves		-	-

PRESSURE TESTING	ACC. ASME B16.34
VALVE DESIGN	ACC. ASME B16.34
END CONN.	SW SCHED.160 ACC. ASME B16.11
HP FIG. NR.	02.1
COATING SYSTEM	FIRST LAYER HEMPEL GALVOSIL 15700 SECOND LAYER HEMPEL SILICONE ALUMINIUM 56910

A	01.02.2010	FIRST ISSUE.	R.T.B	R.K
IZM. REV.	DATA DATE	OPISANE DESCRIPTION	INACERCEND DRN.	RAZR. STR. PROVER. CHK. UTVER. APP.

ЧЕТВЕРТАЯ ГЕНЕРИРУЮЩАЯ КОМПАНИЯ
ОПТОВОГО РЫНКА ЭЛЕКТРОЭНЕРГИИ



ENKA Power Systems B.V.


'YVINSKA' GR_S

YAJVA STATE DISTRICT POWER PLANT

TITLE : FORGED STEEL THROTTLE VALVE
PRESSURE CLASS: 2500 LBS
NOM SIZE: 3/4"

STATUS		REVISIONS									
PRELIMINARY											
FOR LAYOUT											
FOR CONSTRUCTION											
FOR CONSTRUCTION EXCEPT HOLD											
AS BUILT											

Destination		E/01/161031		
YAJVA STATE DISTRICT POWER PLANT		ORDER N°		
Designation		Engineer	LEVAUX	
HP12 SUPERHEATER OUTLET PRESSURE TEST ISOLATION VALVE		Checker	R.K	
		Draftman	R. t. B	
		Name		Signature



This drawing and the design it covers are the property of CMI. They are merely loaned on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited or used except in the limited way of and private use permitted by any written consent given by CMI to the borrower.

N° Draw

66094/23143/2

Scale

Sheet: 1 / 1