




ITEM	QTY	DESCRIPTION	MATERIAL
01	1	BODY	КОРПУС
17	1	SCREEN	ЭКРАН
18	1	BONNET	КОЛПАЧОК
19	1	GASKET	ПРОКЛАДКА
20	1	CAP	КОЛПАЧОК
27	1	SPRINGWASHER	ПРУЖИННАЯ ШАЙБА
32	1	THIN NUT	НИЗКАЯ ГАЙКА
44	1	NAME PLATE	ШИЛЬДИК
			ALUMINIUM
SCREEN PERFORATION: 0.1MM			



HP VALVES REF. : 20100006	P.O. Box 151 7570 AD Oldenzaal The Netherlands Tel +31 (0)541 519555 www.hpvalves.com info@hpvalves.com
APPROVAL : <i>fr</i>	
PROJECT REFERENCE : YAJVINSKAYA CAPP	
CLIENT P/O NO : 203/2010/900588	
CLIENT : CMI	
REQ. NUMBER: 239632	
DESIGN PRESS. DESIGN TEMP.	
TAG NR. BAR (G) °C	
15LAF50AT101 69 285.8	
PRESSURE TESTING ACC. ASME B16.34	
VALVE DESIGN ACC. ASME B16.34	
END CONN. SW SCHED.80 ACC. ASME B16.11	
HP FIG. NR. 08.2	
COATING SYSTEM 1 LAYER HEMPEL SILICONE ZINC 16900	
A 03.02.2010 FIRST ISSUE. R.T.B R.K	
IZN REV. DATA DATE OPISANIE DESCRIPTION NACERENO DRN. RAZR. STR. PROVER. CHK. UTVER. APP.	
 ЧЕТВЕРТАЯ ГЕНЕРИРУЮЩАЯ КОМПАНИЯ ОПТОВОГО РЫНКА ЭЛЕКТРОЭНЕРГИИ	
ENKA Power Systems B.V.	
'YVINSKA' GR_S	
YAJVA STATE DISTRICT POWER PLANT	
TITLE : FORGED STEEL Y-TYPE STRAINER PRESSURE CLASS: 800 LBS NOM SIZE: 2"	
STATUS	REVISIONS
PRELIMINARY FOR LAYOUT FOR CONSTRUCTION FOR CONSTRUCTION EXCEPT HOLD AS BUILT	A
Destination YAJVA STATE DISTRICT POWER PLANT	E/01/161031 ORDER N° Engineer LEVAUX Checker R.K Draftman R.T.B Name Signature
Designation IP DESUPERHEATING STRAINER	 66094/23632/2
This drawing and the design it covers are the property of CMI. They are merely loaned on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited or used except in the limited way of and private use permitted by any written consent given by CMI to the borrower.	
N° Draw	Scale: Sheet: 1 / 1